



**BUREAU
VERITAS**

Certificate of compliance

Applicant: NingBo Deye Inverter Technology Co., Ltd.
No. 26 South YongJiang Road,
Daqi, Beilun, NingBo,
China

Product: Photovoltaic (PV) and battery inverter

Model:

SUN-3K-SG04LP1-EU	SUN-3K-SG04LP1-24-EU-SM1
SUN-3K-SG04LP1-24-EU	SUN-3K-SG04LP1-EU-SM1
SUN-3.6K-SG04LP1-EU	SUN-3.6K-SG04LP1-EU-SM2
SUN-5K-SG04LP1-EU	SUN-5K-SG04LP1-EU-SM2
SUN-6K-SG04LP1-EU	SUN-6K-SG04LP1-EU-SM2

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019-02, NBN EN 50549-1:2019-02

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

C10/11:2021-03

Specific technical requirements for generator in parallel operation with the distribution network

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the representative product listed above corresponds to the stated rules and standards.

Report number: ASUE-ESH-P22010039-R1 **Certification program:** NSOP-0032-DEU-ZE-V01
Certificate number: U23-1079 **Date of issue:** 2023-11-28

Certification body

Domenik Koll
Head of Energy Systems

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH





BUREAU
VERITAS

Annex to the EN 50549-1 / C10/11 certificate of compliance No. U23-1079

Appendix

Extract from test report according to EN 50549-1 / C10/11 Nr. ASUE-ESH-P22010039-R1

Type Approval and declaration of compliance with the requirements of EN 50549-1, Commission Regulation (EU) 2016/631 of 14 April 2016 and C10/11 for Belgium

Manufacturer / applicant	NingBo Deye Inverter Technology Co., Ltd. No. 26 South YongJiang Road, Daqi, Beilun, NingBo, China
---------------------------------	--

Micro-generator Type	Photovoltaic and battery inverter			
-----------------------------	-----------------------------------	--	--	--

	SUN-3K-SG04LP1-EU	SUN-3K-SG04LP1-24-EU	SUN-3.6K-SG04LP1-EU	SUN-5K-SG04LP1-EU
MPP DC voltage range [V]	150-425			
Input DC voltage range [V]	370 (125-500)			
Input DC current [A]	13	13	13/13	13/13
Output AC voltage [V]	L/N/PE 230, 50/60Hz			
Output AC current [A]	13,0	13,0	15,7	21,7
Output power [W]	3000	3000	3600	5000
Battery DC voltage range [V]	48 (40-60)	24 (20-30)	48 (40-60)	48 (40-60)
Battery charge current [A]	70	140	90	120
Battery discharge current [A]	70	140	90	120

	SUN-6K-SG04LP1-EU	SUN-3K-SG04LP1-EU-SM1	SUN-3K-SG04LP1-24-EU-SM1	SUN-3.6K-SG04LP1-EU-SM2
MPP DC voltage range [V]	150-425			
Input DC current [A]	13/13	18		18/18
Output AC voltage [V]	L/N/PE 230, 50/60Hz			
Output AC current [A]	26,1	13,1	13,1	15,7
Output power [W]	6000	3000	3000	3600
Battery DC voltage range [V]	48 (40-60)	48(40-60)	24(20-30)	48(40-60)
Battery charge current [A]	135	70	140	90
Battery discharge current [A]	135	70	140	90

	SUN-5K-SG04LP1-EU-SM2	SUN-6K-SG04LP1-EU-SM2	--	--
MPP DC voltage range [V]	150-425		--	--
Input DC current [A]	18/18		--	--
Output AC voltage [V]	L/N/PE 230 50/60Hz		--	--
Output AC current [A]	21,8	26,1	--	--
Output power [W]	5000	6000	--	--
Battery DC voltage range [V]	48(40-60)		--	--
Battery charge current [A]	120	135	--	--
Battery discharge current [A]	120	135	--	--

Firmware version	4384
-------------------------	------



Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. ASUE-ESH-P22010039-R1

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in (each) line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019, Commission Regulation (EU) 2016/631 of 14 April 2016 and C10/11 for Belgium. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.