

# Certificate of Conformity

By the product certificate number:

No. 230022RECO14-CER

Issued to:

License holder: **NingBo Deye Inverter Technology Co., Ltd.**  
No. 26 South YongJiang Road, Daqi, Beilun, NingBo, China

Trademark:



Manufacturer: **NingBo Deye Inverter Technology Co., Ltd.**  
No. 26 South YongJiang Road, Daqi, Beilun, NingBo, China

It is certified that the product:

Type of generating unit: **Grid-connected PV Inverter**

Models:	SUN-25K-G05	SUN-20K-G05	SUN-18K-G05
Technical Data:			
Nominal power	25000 W	20000 W	18000 W
Nominal voltage	230 V / 400 V [3/N/PE]	230 V / 400 V [3/N/PE]	230 V / 400 V [3/N/PE]
Nominal frequency	50 Hz / 60 Hz	50 Hz / 60 Hz	50 Hz / 60 Hz
Firmware version	5512	5512	5512
Number of phases	Three Phase	Three Phase	Three Phase
Isolation Transformer	No	No	No

Is in compliance with the standard:

**IEC 62116: 2014.** "Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters."

This certificate is based upon the test results of the Test Report GZES230300417902 <sup>(1)</sup>

<sup>(1)</sup> The tests shown in this test report are carried out at a frequency of 50 Hz and 60 Hz

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 08<sup>th</sup> June 2023

This certificate is valid until 08<sup>th</sup> June 2028

Madrid, 08<sup>th</sup> June 2023

Daniel Arranz Muñiz  
Certification Manager

