

CERTIFICATE OF SUITABILITY

Authorised marking: TUV-028293-E

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.

CERTIFICATE HOLDER:

NingBo Deye Inverter Technology
Co., Ltd.
No. 26 South YongJiang Road, Daqi,
Beilun NingBo
315800 Zhejiang
P.R. China

DESCRIPTION OF EQUIPMENT

Declared class:	Non-declared
Product:	Hybrid Inverter
Trade Name / Manufacturer:	DEYE
Model Number:	SUN-5K-SG02LP1-AU-AM2 , SUN-6K-SG02LP1-AU-AM2 , SUN-7.6K-SG02LP1-AU-AM2 , SUN-8K-SG02LP1-AU-AM2 , SUN-10K-SG02LP1-AU-AM3 , SUN-12K-SG02LP1-AU-AM3
Ratings:	Ratings refer to CONTINUATION SHEET 1-2 for details
Standard:	AS/NZS 4777.2:2020+A1 IEC 62109-1:2010 IEC 62109-2:2011
Issue Date:	07/11/2024
Expiry Date:	07/11/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



John Wang



www.jas-anz.org/register

CERTIFICATE OF SUITABILITY

Authorised marking: TUV-028293-E

CONTINUATION SHEET 1

Description of Equipment

Ratings:

Protection: Class I, IP65, PD 2 (Inside), PD 3 (Outside)

Operating Temp.: -40°C to 60°C (Derating at 45°C)

Overvoltage Category (OVC): DC sides: II; AC side: III

Inverter topology: Non-Isolated

Firmware version: 3386

PV input:

Vmax: 500Vdc

VMPP: 150-425 Vdc

Isc: 44/44A, 44/44A, 44/44A, 44/44A, 44/44/44A, 44/44/44A;

Imax: 20/20A, 20/20A, 26/26A, 26/26A, 26/26/26A, 26/26/26A



Battery input:

Battery type: Lithium-ion or Lead-acid

Voltage range: 40-60Vdc

Max charging/discharging current: 120/120A, 135/135A

, 190/190A, 190/190A, 220/220A, 250/250A.

Issue Date: 07/11/2024

Expiry Date: 07/11/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

John Wang



www.jas-anz.org/register

CERTIFICATE OF SUITABILITY

Authorised marking: TUV-028293-E

CONTINUATION SHEET 2

Description of Equipment

AC output(On-grid):

Rated Output voltage: L+N+PE 230/240V

Rated frequency: 50Hz

Rated Output Apparent power: 5000, 6000, 7600, 8000, 9999, 12000VA

Max Output Apparent power: 5000, 6000, 7600, 8000, 9999, 12000VA

Rated Output Power: 5000, 6000, 7600, 8000, 9999, 12000W

Max Output Power: 5000, 6000, 7600, 8000, 9999, 12000W

Max Output Current: 21.8, 26.1, 33.1, 34.8, 43.5, 52.2A

Rated Output Current: 21.8, 26.1, 33.1, 34.8, 43.5, 52.2A

Power factor: 0.8 leading-0.8 lagging

EPS output(with battery)

AC output(Back up):

Rated Output voltage: L+N+PE 230/240V

Rated frequency: 50Hz

Rated Output power: 5000, 6000, 7600, 8000, 9999, 12000W

Rated Output Current: 21.8, 26.1, 33.1, 34.8, 43.5, 52.2A

Issue Date: 07/11/2024

Expiry Date: 07/11/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



John Wang



www.jas-anz.org/register