

Certificate of Conformity (COC)

SGS

Certificate Holder : Ningbo Deye Inverter Technology Co., Ltd.
No. 26 South Yongjiang Road, Daqi, Beilun, NingBo, China

Date of Original Issue : 2024-11-19


Date of Last Revision : --

Date of Expiry : 2027-11-18

Certificate Number : PCS-24-1168

Product : Hybrid Inverter

Ratings : See appendix on page 2

Brand/Trademark : 

Model(s) : See appendix on page 2

Test Laboratory : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch

Testing Report : GZES230400660001 Amendment 01, GZES230400660002 Amendment 01,
GZES230400660003 Amendment 01 and GZES230400660004 Amendment 01

Test Standard : IEC 61727: 2004, IEC 62116: 2014, IEC 61683: 1999, IEC 60068-2-1: 2007, IEC 60068-2-2: 2007,
IEC 60068-2-14: 2009 and IEC 60068-2-30: 2005



This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).
The above-mentioned product is certified according to the requirements of ISO/IEC 17065:2012.

Christopher Hee
Certification Officer

SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way #03-01 Singapore 609957



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

APPENDIX

Certificate Number: PCS-24-1168

Model	SUN-14K-SG05LP3-EU-SM2	SUN-15K-SG05LP3-EU-SM2	SUN-16K-SG05LP3-EU-SM2	SUN-18K-SG05LP3-EU-SM2	SUN-20K-SG05LP3-EU-SM2
PV Input					
Max. input voltage(V)	800				
Start-up operating voltage(V)	160				
Rated input voltage(V)	550				
MPPT Voltage Rang(V)	160~650				
Full power MPPT voltage range(V)	310~650	330~650	350~650	400~650	440~650
Max. input current(A)	36+36				
Max. short current(A)	54+54				
Battery Input					
Battery Type	Lead-acid or Lithium-ion				
Battery Voltage Range(V)	40~60				
Max. Charging/ Discharging Current(A)	260	280	300	330	350
AC Output					
Nominal grid voltage(V)	230/400 3L+N+PE				
Nominal grid frequency (Hz)	50/60				
Rated AC power(W)	14000	15000	16000	18000	20000
Max. AC Apparent power(kVA)	15400	16500	17600	19800	22000
Rated AC current(A)	20.3	21.8	23.2	26.1	29.0
Max. AC current(A)	22.4	24.0	25.6	28.7	31.9
Output power factor	0.8 leading to 0.8 lagging				
General Data					
Operating temperature range	-40 °C ~ +60 °C (Above 45 °C Derating)				
Protection degree	IP65				
Protective class	Class I				
Cooling method	Intelligent Air cooling				
Topology	Non-Isolated				



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.