

Certificate of Conformity (COC)



Certificate Holder : NingBo Deye Inverter Technology Co., Ltd.
No. 26 South YongJiang Road, Daqi, Beilun, NingBo, Zhejiang, China

Date of Original Issue : 2026-02-04

Date of Last Revision : --

Date of Expiry : 2029-02-03

Certificate Number : PCS-26-1020

Product : Hybrid Inverter

Ratings : See appendix on page 2

Brand/Trademark : **Deye**

Model(s) : SUN-12K-SG01LP1-EU-AM3-P, SUN-14K-SG01LP1-EU-AM3-P,
SUN-16K-SG01LP1-EU-AM3-P, SUN-18K-SG01LP1-EU-AM3-P

Test Laboratory : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch

Testing Report : GZGC260100001501, GZGC260100001502, GZGC260100001503 and GZGC260100001504

Test Standard : IEC 62116:2014, IEC 61727:2004, IEC 61683:1999, IEC 60068-2-1:2007, IEC 60068-2-2:2007,
IEC 60068-2-14:2009 and IEC 60068-2-30:2005




This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).
The above-mentioned product is certified according to the requirements of ISO/IEC 17065:2012.

Christopher Hee
Certification Officer

SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way #03-01 Singapore 609957



PD-2016-15




The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

APPENDIX

Certificate Number: PCS-26-1020

Product Model	SUN-12K-SG01LP1-EU-AM3-P	SUN-14K-SG01LP1-EU-AM3-P	SUN-16K-SG01LP1-EU-AM3-P	SUN-18K-SG01LP1-EU-AM3-P
Input (PV)				
Max. PV Input Power (W)	19200	22400	25600	28800
Max. PV Input Voltage (V)		500		
Start-up Voltage (V)		125		
Rated Input Voltage (V)		370		
MPPT Voltage Range (V)		150 ~ 425		
Full Load MPPT Voltage Range (V)		250 ~ 425		
Max. Operating PV Input Current (A)	36+36+36	36+36+36	36+36+36	36+36+36
Max. Input Short-Circuit Current (A)	54+54+54	54+54+54	54+54+54	54+54+54
No. of MPP Trackers/No. of Strings MPP Tracker		3/2+2+2		
Battery Input				
Battery Type		Lead-acid or Lithium-ion		
Battery Voltage Range (V)		40-60		
Max. Charging Current (A)	220	250	290	380
Max. Discharging Current (A)	220	250	290	380
Output (AC)				
Rated AC Output Active Power (W)	12000	14000	16000	18000
Max. AC Output Apparent Power (W)	13200	15400	17600	19800
Rated AC Output Current (A)	52.2	60.9	69.6	78.3
Max. AC Output Current (A)	57.4	67.0	76.6	86.1
Nominal Grid Voltage (V)		L/N/PE, 230		
Nominal Frequency (Hz)		50/60		
Power Factor		0.8 leading - 0.8 lagging		
General Data				
Topology		Non-Isolated		
Operating Temperature Range		-40 ~ +60 °C, > +45 °C derating		
Degree of Protection		IP65		
Type of Cooling		Intelligent Air Cooling		



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.