



太阳能产品认证证书

证书编号：CQC18024199048

申请人名称及地址

宁波德业变频技术有限公司
浙江省宁波市北仑区大碶甬江南路26号

制造商名称及地址

宁波德业变频技术有限公司
浙江省宁波市北仑区大碶甬江南路26号

生产企业名称及地址

宁波德业变频技术有限公司(V027577)
浙江省宁波市北仑区大碶甬江南路26号

产品名称和系列、规格、型号

光伏并网逆变器

SUN-33K-G、SUN-40K-G、SUN-50K-G、SUN-60K-G (见附件)

产品标准和技术要求

NB/T32004-2013(IIIa, 不含低电压穿越试验)

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2013 认证规则的要求，特发此证。

发证日期：2018年08月06日

本证书的有效性依据发证机构的定期监督获得保持。



主任：_____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0008246



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC18024199048

NAME AND ADDRESS OF THE APPLICANT

NingBo Deye Inverter Technology Co.,Ltd
No.26,South YongJiang Road,Beilun,NingBo,China

NAME AND ADDRESS OF THE MANUFACTURER

NingBo Deye Inverter Technology Co.,Ltd
No.26,South YongJiang Road,Beilun,NingBo,China

NAME AND ADDRESS OF THE FACTORY

NingBo Deye Inverter Technology Co.,Ltd (V027577)
No.26,South YongJiang Road,Beilun,NingBo,China

PRODUCT NAME, MODEL AND SPECIFICATION

PV Grid-Connected Inverter
SUN-33K-G、SUN-40K-G、SUN-50K-G、SUN-60K-G (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa, Without Low Voltage Ride Through Test)

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2013 .

Valid from: Aug.06,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.



President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

T 0008246



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18024199048

纸 号: 8246

SUN-33K-G

直流输入:MPPT 电压范围250V-950Vdc,最大直流输入电压1000Vdc,最大输入电流28.5A*2;
交流输出:3P/PE~, 220/380V, 50Hz, 额定电流50A*3, 额定交流输出功率33kW;

SUN-40K-G

直流输入:MPPT 电压范围250V-950Vdc,最大直流输入电压1000Vdc,最大输入电流28.5A*3;
交流输出:3P/PE~, 220/380V, 50Hz, 额定电流60.6A*3, 额定交流输出功率40kW;

SUN-50K-G

直流输入:MPPT 电压范围250V-950Vdc,最大直流输入电压1000Vdc,最大输入电流28.5A*3;
交流输出:3P/PE~, 220/380V, 50Hz, 额定电流75.8A*3, 额定交流输出功率50kW;

SUN-60K-G

直流输入:MPPT 电压范围250V-950Vdc,最大直流输入电压1000Vdc,最大输入电流28.5A*4;
交流输出:3P/PE~, 220/380V, 50Hz, 额定电流90.9A*3, 额定交流输出功率60kW.

注: 此附录与证书同时使用时有效。



主任: _____

A handwritten signature in black ink, written over a horizontal line.



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>