

Certificate of Conformity

By the product certificate number:

No. 2621/0125-B-E1-CER/E1

Issued to:

License holder: **NingBo Deye Inverter Technology Co., Ltd.**
No.26 South YongJiang Road, Daqi, Beilun, NingBo,, China

Trademark:



Manufacturer: **NingBo Deye Inverter Technology Co., Ltd.**
No.26 South YongJiang Road, Daqi, Beilun, NingBo,, China

It is certified that the product

Type of generating unit: PV Solar Grid Tie Inverter

Models:	SUN-70K-G03	SUN-75K-G03	SUN-80K-G03	SUN-90K-G03	SUN-100K-G03	SUN-110K-G03
Technical Data:						
Nominal power	70 kW	75 kW	80 kW	90 kW	100 kW	110 kW
Nominal voltage	230 / 400 V _{ac}					
Nominal frequency	50 / 60 Hz					
Firmware version	Ver3205					
Number of phases	Three Phase (3/N/PE)					
Isolation Transformer	No					

Is in compliance with the standard:

- IEC 62116:2014 “Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.”

This certificate is based upon the test results of the Test Report BL-DG21350952-201⁽¹⁾

⁽¹⁾ The tests shown in this test report are carried out at a frequency of 50/60 Hz.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 04th January 2024

This certificate is valid until 14th June 2029

Madrid, 30th May 2024.

Daniel Arranz Muñiz
Certification Manager



SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions.
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).
This document cannot be reproduced partially.



No. 2621/0125-B-E1-CER/E1