

# Certificate of Conformity

By the product certificate number:

No. 2618/0978-B-CER/E2

Issued to:

License holder:

NingBo Deye Inverter Technology Co., Ltd.  
No. 26 South YongJiang Road, Daqi, Beilun, NingBo, China

Trademark:



Manufacturer:

NingBo Deye Inverter Technology Co., Ltd.  
No. 26 South YongJiang Road, Daqi, Beilun, NingBo, China

It is certified that the product:

Type of generating unit: Utility Interactive Inverter

Models:

SUN-60K-G  
SUN-56K-G

SUN-70K-G

SUN-75K-G

SUN-80K-G

Technical data:

Nominal power [W]

60 kW

70 kW

75 kW

80 kW

Nominal voltage [V]

230/400 V<sub>AC</sub>

Nominal frequency [Hz]

50/60 Hz

Firmware version

Display software version: Ver 150

Control software version: Ver 1702

Number of phases

Three-phase  
(3L/N/PE)

Isolation transformer

No

Is in compliance with the standard:

- IEC 62116: 2014, "Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters."

This certificate is based upon the test results of the Test Report 2218/0978-B-E1 <sup>(1)</sup>.

<sup>(1)</sup> The tests shown in this test report are carried out at a frequency of 50 Hz.

The production of the above-mentioned units is covered by this certificate when they are manufactured in the addressed factory location as identical to the tested sample and remains in compliance with referred standards.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 16<sup>th</sup> November 2018.

This certificate is valid until 16<sup>th</sup> November 2031.

Madrid, 9<sup>th</sup> April 2026

Daniel Arranz Muñiz  
Certification Manager

