


CERTIFICATE OF CONFORMITY

Applicant:	NingBo Deye Inverter Technology Co.,Ltd. No.26 South Yongjiang Road, Daqi, Beilun, Ningbo, China		
Product:	PV inverter with integrated AFPE function		
Model(s):	SUN-3.6K-G05P1-EU-AM2, SUN-4.6K-G05P1-EU-AM2, SUN-6K-G05P1-EU-AM2, SUN-3.6K-G05P1-EU-CM2, SUN-4.6K-G05P1-EU-CM2, SUN-6K-G05P1-EU-CM2,	SUN-4K-G05P1-EU-AM2, SUN-5K-G05P1-EU-AM2, SUN-6.2K-G05P1-EU-AM2; SUN-4K-G05P1-EU-CM2, SUN-5K-G05P1-EU-CM2, SUN-6.2K-G05P1-EU-CM2	SUN-4.2K-G05P1-EU-AM2, SUN-5.2K-G05P1-EU-AM2; SUN-4.2K-G05P1-EU-CM2, SUN-5.2K-G05P1-EU-CM2,
Trademark:			
Technical data:	Nominal active output power [kW]:	3.6 ~ 6.2	
	Nominal output AC voltage [V]:	220 / 230 (L + N + PE, 50 / 60 Hz)	
	(For further details see A.2 on p.2)		
Software version:	Inv 8556-0105		
Applied standard(s) / guideline(s):	IEC 63027:2023 Photovoltaic power systems - DC arc detection and interruption		
Certification scheme:	CMPD-01 (Type 1a Certification in accordance with ISO/IEC 17067)		
Test report no.:	LS2A26012201EGIE03 (2026-04-15)		

This certificate confirms that the integrated AFPE function of the inverter models listed above was evaluated and found to comply, within the scope defined herein, with the applicable requirements of IEC 63027:2023 at the time of issuance.

The scope of this certificate is limited to the inverter-integrated AFPE for string-inverter application in accordance with Annex B.2 of IEC 63027:2023. The certified scope covers the applicable classification, ratings, product information, construction and performance requirements, series arc fault tests, self-test function, and manual reconnection requirements, as documented in the relevant test report.

No conformity is implied for micro-inverter application, module-level DC/DC conversion application, or external combined-string application.

This certificate is issued as a **Type 1a Certification in accordance with ISO/IEC 17067**. It is based solely on type testing of the identified sample product(s) and the specific tests undertaken. It does not extend to production or ongoing manufacturing.

No certification mark is authorized for this certification scheme. No factory surveillance or follow-up is performed. This certificate becomes void if any modification is made to the certified product, its installation, erection, or commissioning that may affect compliance with the evaluated requirements.

This certificate does not imply LYNS's endorsement, approval, certification, or ongoing control of the product(s), either in terms of performance, design, manufacture, or materials used. The certificate and the results stated herein relate solely to the sample product(s) tested and to the specific tests undertaken.

The certificate will remain valid for the stated period provided that no changes are made to the product, production method, or relevant certification scheme. This certificate is only valid when it is also found at <http://www.lyns-tci.com/en/certificate-search> or by contacting Lyns-tci Technology Guangdong Co., Ltd..

This certificate is for the exclusive use of LYNS's Client and is provided pursuant to the agreement between LYNS and its Client. LYNS's responsibility and liability are limited to the terms and conditions of the agreement. LYNS assumes no liability to any party other than the Client, in accordance with the agreement, for any loss, expense, or damage occasioned by the use of this certification.

The certificate is comprised of 3 pages (including Annex of 2 pages).

Dongguan, 2026-04-27

Dipl.-Ing. Weizhao Zheng
Head of certification body

Certification body Lyns-tci Technology Guangdong Co., Ltd. accredited according to ISO/IEC 17065 for product certification.

This document shall not be reproduced, except in full, without the written approval of Lyns-tci Technology Guangdong Co., Ltd.

A.1 Revision history of the certificate

Rev. No.	Date	Changes	Status
0	2026-04-27	Initial issue	Active

A.2 Technical data of the power generating unit(s)

Model	SUN-3.6K-G05P1-EU-AM2	SUN-4K-G05P1-EU-AM2	SUN-4.2K-G05P1-EU-AM2
	SUN-3.6K-G05P1-EU-CM2	SUN-4K-G05P1-EU-CM2	SUN-4.2K-G05P1-EU-CM2
Input PV (DC)			
Max. DC input voltage [V]	550		
Operating MPPT voltage range [V]	70 - 500		
Max. input DC current [A]	18 / 18		
Max. Short Circuit current [A]	27 / 27		
No. of MPP Trackers	2		
No. of strings per MPP Tracker	1		
Output (AC)			
Rated output AC voltage [V]	220 / 230 (L + N + PE, 50 / 60 Hz)		
Max. Output AC current [A]	18.0 / 17.3	20.0 / 19.2	21.0 / 20.1
Rated active power [kW]	3.6	4.0	4.2
Max. apparent power [kVA]	3.96	4.40	4.62

Model	SUN-4.6K-G05P1-EU-AM2	SUN-5K-G05P1-EU-AM2	SUN-5.2K-G05P1-EU-AM2
	SUN-4.6K-G05P1-EU-CM2	SUN-5K-G05P1-EU-CM2	SUN-5.2K-G05P1-EU-CM2
Input PV (DC)			
Max. DC input voltage [V]	550		
Operating MPPT voltage range [V]	70 - 500		
Max. input DC current [A]	18 / 18		
Max. Short Circuit current [A]	27 / 27		
No. of MPP Trackers	2		
No. of strings per MPP Tracker	1		
Output (AC)			
Rated output AC voltage [V]	220 / 230 (L + N + PE, 50 / 60 Hz)		
Max. Output AC current [A]	23.0 / 22.0	25.0 / 24.0	26.0 / 24.9
Rated active power [kW]	4.6	5.0	5.2
Max. apparent power [kVA]	5.06	5.50	5.72

Model	SUN-6K-G05P1-EU-AM2	SUN-6.2K-G05P1-EU-AM2
	SUN-6K-G05P1-EU-CM2	SUN-6.2K-G05P1-EU-CM2
Input PV (DC)		
Max. DC input voltage [V]	550	
Operating MPPT voltage range [V]	70 - 500	
Max. input DC current [A]	18 / 18	
Max. Short Circuit current [A]	27 / 27	
No. of MPP Trackers	2	
No. of strings per MPP Tracker	1	

Annex to the Certificate No.: LS260099GCC-0

Output (AC)		
Rated output AC voltage [V]	220 / 230 (L + N + PE, 50 / 60 Hz)	
Max. Output AC current [A]	30.0 / 28.7	31.0 / 29.7
Rated active power [kW]	6.0	6.2
Max. apparent power [kVA]	6.60	6.82
Operating temperature range	-25°C - 60°C	
Degree of protection	IP65	
Protection class	I	
Overvoltage category	AC: III; DC: II	
Topology	No galvanic isolation	
AFPE / AFCI classification	F-I-AFPE-1-2-1	
Software version	Inv 8556-0105	
Manufacturing factory	NingBo Deye Inverter Technology Co.,Ltd. No.26 South YongJiang Road, Daqi, Beilun, Ningbo, China	

A.3 Remarks for type testing

Testing laboratory	Lyns-tci Technology Guangdong Co., Ltd. Room 1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960 P.R.C (Accredited acc. ISO/IEC 17025: A2LA Accreditation no. 5200.02)
Testing location	Same as above
Measurement period	2026-01-22 - 2026-03-18